

**PHYSICAL TESTING REPORT**

Reviglass SA
Ctra. Tolosa-Azpeitia, Km 8
Bidania
20496
Spain

FAO: Y Otamendi

REPORT OF TESTS ON: Glass Mosaic

Your Reference: 25x25mm Antislip

CERAM Reference: (072511)-12860

Date Reported: 16-May-2007

Order Number:

Date Logged: 08-May-2007

Date(s) of Test(s): 09-May-2007 to 11-May-2007

Inclined Platform Test for Slip Resistance of Flooring Materials Under Wet Barefoot Conditions

DIN 51097: 1992

No.	Operator 1- Barefoot Results	Operator 2- Barefoot Results
	*	*
1	30.0	30.0
2	30.0	30.0
3	30.0	30.0
4	30.0	30.0

Description of Test Specimen(s): 1 panel - 1 x 0.5m

Average Barefoot Result: 30.0 °

Category: C

The critical angle at which 2 test persons reach the limit of safe walking on an inclined plane is used as a measure of slip resistance.

End of Test Report

